

# UNDERGROUND SERVICE SPEC SHEET

\*FCEC WILL NOT HOOK UP POWER ON UNDERGROUND SERVICES THAT DO NOT MEET THESE REQUIREMENTS.  
(PVC MUST BE 3' DEEP)

